

Manufactured Home Service Pole for Underground Service

Bill of Materials

1. (1) 2x6x8' (Treated)
2. (2) 4x4x8' (Treated)
3. 2 Lag Screws
4. Mobil Home Disconnect (Approved)
5. Meter Base Appoved
6. (1) Conduit Clamp
7. (1) 5/8" x 5' Ground Rod
8. 6 ft. #4 Bare Copper Ground Wire
9. (1) Gronund Rod Clamp
- 10 6 ft. Schedule 80 PVC Conduit
11. (1) Schedule 80 PVC 90 degree elbow (12" Radius)
12. (1) Schedule 40 PVC 90 degree elbow (24" Radius)